

Acoustic Testing Laboratory College of Science & Technology The University of Salford Salford, Greater Manchester M5 4WT, United Kingdom

T: +44 (0) 161 295 4615 F: +44 (0) 161 295 4456 E: d.j.mccaul@salford.ac.uk

TEST REPORT No : 5339-01 Page 1 of 11

DATE OF ISSUE : 09 July 2021

# BS EN ISO 10534-2:2001

# **ACOUSTICS – DETERMINATION OF SOUND ABSORPTION COEFFICIENT AND IMPEDANCE IN IMPEDANCE TUBES – Part 2: Transfer Function Method**

**CLIENT:** 

**JOB NUMBER:** 

**DATE OF TEST:** 

**MODEL:** 

S M Furlong

**MANUFACTURER:** 

**DATE ORDER RECEIVED:** 

**Camira Fabrics Limited** Meltham Mills Meltham Holmfirth West Yorkshire HD9 4AY 05339 Client Quest 14 June 2021 09 July 2021

Signed:

(anoi Approved:...

Specialist Acoustics Technician

Claire Lomax Quality Manager

### <u>1</u> <u>TEST SAMPLES</u>

#### **1.1** Description of Test Samples

Test Reference:5339-01Sample Reference:QuestSample Description:Fabric over Melamine Foam\*

Four samples cut to100 mm diameter and 0.9 mm thickness, and four samples cut to 29 mm and 0.9 mm thickness were submitted for testing. The samples were mounted loose, over a (nominal) 100 mm layer of melamine foam\*, in the large and small sample holders of the impedance tube respectively. The samples were tested with the side marked by the client as "FACE" towards the sound source.

Large mass per unit area:	0.3 kg/m <sup>2</sup>
Small mass per unit area:	$0.3 \text{ kg/m}^2$
Visible Layers:	None

\*The results from the sound absorption coefficient tests for the uncovered melamine foam are included in an appendix, at the end of this report.

### 1.2 Photograph



## <u>2</u> <u>DESCRIPTION OF TEST PROCEDURE</u>

### 2.1 Description of Test Equipment




Figure 1: Brüel and Kjær Type 4206 Impedance Tube Components

The samples were tested in the Brüel and Kjær Type 4206 Impedance Tube, which has adapters for both large and small sample holders. When using the small sample adaptation there are five possible <sup>1</sup>/<sub>4</sub> inch microphone slots, with a 20 mm spacing between the two microphone positions used during this test. When using the large sample adaptation there are three possible <sup>1</sup>/<sub>4</sub> inch microphone slots, with a 100 mm spacing between the two microphone positions used in this test. Both microphones have a polarisation voltage of 200 V.

The small sample holder contains a plunger capable of adjusting the sample position and providing an air gap to the rear of the sample if desired. The large sample holder has a fitting device to ensure the sample remains flush to the edge of the holder.

The tube also contains a loudspeaker at one end with its own frequency-weighting unit capable of providing a high-pass filter (for high frequency measurements), linear filter, and low pass filter (for extra accuracy in low frequency measurements). The loudspeaker has a diameter of 80 mm and nominal impedance of 4  $\Omega$ . The maximum rated input power to the loudspeaker is 10 W (at 20 °C) so voltage supplied to the loudspeaker is kept at 1.141 V during the test. The default filter used for the loudspeaker is linear.

The tube is connected to its accompanying Brüel and Kjær PULSE Front-End Analyser, which works as a real-time analyser with a pre-installed software package to control the analyser from a PC and perform the measurement calculations.

#### 2.2 Test Procedure

The test procedure follows that detailed in BS EN ISO 10534-2. The PULSE Front-End analyser is connected to a PC via a LAN cable, and the <sup>1</sup>/<sub>4</sub> inch microphones connected to the LEMO inputs on the analyser. The analyser is also connected to an amplifier. The loudspeaker is powered via the amplifier, with a voltmeter also connected to ensure correct input signal to the loudspeaker. The large/small sample holder is attached to the tube.

Prior to measurement, the atmospheric pressure, temperature and humidity are recorded, the microphones are calibrated through the analyser software, the signal-to-noise ratio is calculated, and a Transfer-Function calibration is also performed.

The large/small sample holder is removed and the sample placed in the holder and is checked to ensure it is flush to the edge of the holder, and no air gaps appear around the diameter of the sample. A broadband random noise is generated by the loudspeaker and the incident and reflected components of the sound field are measured by the two microphones in their appropriate positions. This is repeated with the microphone positions interchanged. Three frequency response functions from the measurements are then used by the software to calculate the reflection and absorption coefficients.

#### 2.3 Calculations

The normal incidence absorption coefficient ( $\alpha$ ) is calculated using the following equation:

$$\alpha = 1 - |R|^2$$

Where,

*R* is complex reflection coefficient;

$$R = \left(\frac{H_{12} - H_i}{H_r - H_{12}}\right) e^{2jk_0 x_1}$$

Within that,

 $H_{12}$  is the complex acoustic transfer function between the two microphone signals;

$$H_{12} = H_r + jH_i$$

And,

*j* is the complex integer equivalent to  $\sqrt{-1}$ ;

 $H_i$  is the incident component frequency response function (the complex part of  $H_{12}$ );

 $H_r$  is the reflected component frequency response function (the real part of  $H_{12}$ );  $k_0$  is the wavenumber in radians per metre;

 $x_1$  is the distance between the sample and the further microphone location in metres.

The two microphone transfer function method described in BS EN ISO 10534-2:2001 makes the assumption on plane wave propagation within the tube with no mean flow and negligible losses or absorption along the tube wall. Specifications of the Brüel and Kjær Type 4206

Impedance Tube as provided by the manufacturer can be made available on request.

# **3 EQUIPMENT**

## Departmental Record No

•	Brüel and Kjær Type 4206 Impedance Tube	2681869
•	Brüel and Kjær PULSE Front-End Generator	2477213/ PULSE N.2
•	Dial-A-Watt Power Amplifier	129003364
•	Two Brüel and Kjær ¼ Inch Condenser microphones (attached by tape to their LEMO cables)	2677385 & 2677391
•	Calibrator	1795258
•	Model DA212 AVO avometer	129006085
•	Four Banana-Banana cables	

- BNC-BNC cable
- LAN cable
- Laptop or PC supporting the B&K PULSE Software, with accompanying PULSE Dongle

# <u>4</u> <u>RESULTS</u>

The random incidence sound absorption coefficients are given in the tables overleaf.

Large sample thickness	0.9 mm	
Large sample area	$0.007854 \text{ m}^2$	
Large sample mass per unit area	0.3 kgm <sup>-2</sup>	
Small sample thickness	0.9 mm	
Small sample area	0.000661 m <sup>2</sup>	
Small sample mass per unit area	0.3 kgm <sup>-2</sup>	
	Large Sample	Small Sample
Temperature [°C $\pm 0.3$ ]	21.1	21.7
Rel. humidity [% $\pm$ 3.0]	56.8	53.9
Atm. Pressure [kPa $\pm 0.2$ ]	101.7	101.6

The results here presented relate only to the items tested and described in this report.

# BS EN ISO 10534-2:2001 Acoustics - Determination of Sound Absorption Coefficient in Impedance Tubes; Transfer Function Method

Client: Product Identification: Description of Sample: Curing Time:	Camira Fabrics L Quest Fabric over Melami Not Applicat	ne Foam	
Large Sample [50-1600Hz]		Small Sample [500-5000Hz]	
Temperature:	21.1 °C	Temperature:	21.7 °C
Humidity:	56.8 %	Humidity:	53.9 %
Atmos. Pressure:	101.7 kPa	Atmos. Pressure:	101.6 kPa
Diameter:	100.0 mm	Diameter:	29.0 mm
Thickness:	0.9 mm	Thickness:	0.9 mm
Mass per Unit Area:	0.3 kg/m <sup>2</sup>	Mass per Unit Area:	0.3 kg/m <sup>2</sup>
Condition:	Satisfactory	Condition:	Satisfactory

## Normal incidence sound absorption coefficient, $\alpha_s$

Frequency	α <sub>S</sub> Large	$\alpha_{S}$ Small	α <sub>S</sub> Total
[Hz]	[50-1600]	[500-5000]	[50-5000]
50	0.05		0.05
63	0.16		0.16
80	0.13		0.13
100	0.27		0.27
125	0.36		0.36
160	0.52		0.52
200	0.67		0.67
250	0.80		0.80
315	0.89		0.89
400	0.93		0.93
500	0.94	0.93	0.94
630	0.94	0.94	0.94
800	0.96	0.93	0.94
1000	0.80	0.90	0.85
1250	0.83	0.88	0.86
1600	0.89	0.88	0.88
2000		0.89	0.89
2500		0.86	0.86
3150		0.83	0.83
4000		0.84	0.84
5000		0.82	0.82

#### Test reference: 5339-01

Date of Test: 09 July 2021

University of Salford, School of Computing Science & Engineering

# BS EN ISO 10534-2:2001 Acoustics - Determination of Sound Absorption **Coefficient in Impedance Tubes; Transfer Function Method**

Client: Product Identification:	Car	nira Fabrics Limited Quest	
Description of Sample:	Fabric	over Melamine Foam	
Curing Time:		Not Applicable	
Large Sample [50-1600H	lz]	Small Sample [500-500	<u>00Hz]</u>
Temperature:	21.1 °C	Temperature:	21.7 °C
Humidity:	56.8 %	Humidity:	53.9 %
Atmos. Pressure:	101.7 kPa	Atmos. Pressure:	101.6 kPa
Diameter:	100.0 mm	Diameter:	29.0 mm
Thickness:	0.9 mm	Thickness:	0.9 mm
Mass per Unit Area:	0.3 kg/m <sup>2</sup>	Mass per Unit Area:	0.3 kg/m <sup>2</sup>
Condition:	Satisfactory	Condition:	Satisfactory

# Normal incidence sound absorption coefficient, $\alpha_s$

Frequency	α <sub>S</sub>	1														•								- 3	
[Hz]	[50-5000]				1.2	T															Т	Г			
50	0.05	1			1 1																				
63	0.16				1.1																				
80	0.13				1.0	+											_	_			+	-			
100	0.27																_								
125	0.36			8	0.9 ک	+												Y		+		$\Box$			
160	0.52			ţ	5 0.8																				
200	0.67			ucie	5							/													
250	0.80			effi	0.8	+						$\vdash$				$\left  \right $	$\neg$	+			+	$\vdash$	$\left  \right $		
315	0.89			Ĉ	} 																				
400	0.93			tior	20.0						/														
500	0.94			orp	<u>5</u> 0.5	+				-								_			_	-			
630	0.94			Ahs						/															
800	0.94			pu	<b>5</b> 0.4	$\top$															$\top$				
1000	0.85			201	0.3	+			Α												+				
1250	0.86																								
1600	0.88				0.2	+		/													+	$\vdash$			
2000	0.89	1			0.1																				
2500	0.86				0.1																				
3150	0.83	1			0.0	4													_	-	-	-			
4000	0.84					50	8	0	12	25	20	00		15	50		80		1250	) 2	2000	31	150	500	00
5000	0.82												F	req	lne	ncy	, Η:	Z							
													Si	gn	ed:		2	•	<i>//</i>	V].	1	Z	w	1	m

#### Test reference: 5339-01

Date of Test: 09 July 2021

University of Salford, School of Computing Science & Engineering

## <u>5</u> <u>APPENDIX</u>

# BS EN ISO 10534-2:2001 Acoustics - Determination of Sound Absorption Coefficient in Impedance Tubes; Transfer Function Method

Client: Product Identification: Description of Sample:	Camira Fabrics I Melamine Fo Foam		
Curing Time:	Not Applicat	ble	
Large Sample [50-1600Hz]		Small Sample [500-5000Hz]	
Temperature:	21.1 °C	Temperature:	21.7 °C
Humidity:	56.8 %	Humidity:	53.9 %
Atmos. Pressure:	101.7 kPa	Atmos. Pressure:	101.6 kPa
Diameter:	100.0 mm	Diameter:	29.0 mm
Thickness:	104.0 mm	Thickness:	101.5 mm
Mass per Unit Area:	0.9 kg/m <sup>2</sup>	Mass per Unit Area:	0.9 kg/m <sup>2</sup>
Condition:	Satisfactory	Condition:	Satisfactory

## Normal incidence sound absorption coefficient, $\alpha_s$

Frequency	α <sub>S</sub> Large	$\alpha_{S}$ Small	α <sub>S</sub> Total
[Hz]	[50-1600]	[500-5000]	[50-5000]
50	0.04		0.04
63	0.14		0.14
80	0.13		0.13
100	0.23		0.23
125	0.28		0.28
160	0.40		0.40
200	0.53		0.53
250	0.64		0.64
315	0.74		0.74
400	0.83		0.83
500	0.88	0.89	0.89
630	0.91	0.95	0.93
800	0.89	0.98	0.94
1000	0.95	0.98	0.96
1250	0.94	0.97	0.95
1600	0.95	0.94	0.95
2000		0.98	0.98
2500		0.99	0.99
3150		0.99	0.99
4000		1.00	1.00
5000		1.00	1.00

#### Test reference: 5339-10

Date of Test: 09 July 2021

University of Salford, School of Computing Science & Engineering

# BS EN ISO 10534-2:2001 Acoustics - Determination of Sound Absorption Coefficient in Impedance Tubes; Transfer Function Method

Client: Product Identification:		Camira Fabrics Limited Melamine Foam	
Description of Sample:		Foam	
Curing Time:		Not Applicable	
Large Sample [50-1600]	Hz]	Small Sample [500-	<u>5000Hz]</u>
Temperature:	21.1 °C	Temperature:	21.7 °C
Humidity:	56.8 %	Humidity:	53.9 %
Atmos. Pressure:	101.7 kPa	Atmos. Pressure:	101.6 kPa
Diameter:	100.0 mm	Diameter:	29.0 mm
Thickness:	104.0 mm	Thickness:	101.5 mm
Mass per Unit Area:	0.9 kg/m	<sup>2</sup> Mass per Unit Area	: 0.9 kg/m <sup>2</sup>
Condition:	Satisfactory	y Condition:	Satisfactory

## Normal incidence sound absorption coefficient, $\alpha_s$

Frequency	α <sub>S</sub>			-		-									-			_	-	,	- 3
[Hz]	[50-5000]		1.2				Т									Т					
50	0.04		1.4																		
63	0.14		1.1																		
80	0.13		1.0	-			_								_						
100	0.23														$\wedge$	+					
125	0.28		0.9 ح	+			+								+	$\uparrow$					
160	0.40																				
200	0.53		Sound Absorption Coeffincient, 90 0.0 20 80 20 80 80 20 80 80 80 80 80 80 80 80 80 80 80 80 80																		
250	0.64		ٿ <u>ا</u> ا	+			+					_			+						
315	0.74		С С П б							/											
400	0.83		tior						/												
500	0.89		d 0.5	+			+	$\square$		_		_		_	_	-					
630	0.93		Abs																		
800	0.94		р <sup>0.4</sup>				1														
1000	0.96		0 S 0.3	-			$\downarrow$								_						
1250	0.95						1														
1600	0.95		0.2	+			+								+	1					
2000	0.98		0.1		$\bowtie$																
2500	0.99																				
3150	0.99		0.0			+		$\square$			-	_									
4000	1.00			50	80	1	L25	20	00	31 5		50		80 		250	20	00	31	50	500
5000	1.00									F	req	ue	ncy	γ, Η:	Z						
										Si	gne	ed:	_	Ĺ	>.	//	V].	1	L	-	Í.
<b>T</b>		0.40								_			<u>ст</u>	1	. 00	Luk		~~~			

#### Test reference: 5339-10

Date of Test: 09 July 2021

University of Salford, School of Computing Science & Engineering