



Date of Issue: 4/25/2024 Report Number: 24-000963

Revision Number:1

Date Order Received: 04/19/2024

For the Account of: Camira Fabrics Ltd.

Meltham Mills Meltham

Holmfirth, West Yorkshire HD9 4AY

United Kingdom

Client's Identification: Blazer-FR Treatment Z

CERTIFICATE OF TESTING

TEST PERFORMED: NFPA 701 Standard Methods of Fire Test for Flame Propagation of Textiles and Films 2019 – Test #1

TEST RESULTS

Specimen	Mass Initial (g)	Mass Final (g)	Mass Loss (%)	Drip Burn (s)	Afterflame (s)
1	31.5	24.5	22	0.0	8.0
2	31.1	23.3	25	0.0	4.0
3	31.4	25.9	18	0.0	0.0
4	31.3	29.4	6	0.0	0.0
5	31.6	26.2	17	0.0	3.0
6	31.6	23.2	27	0.0	0.0
7	31.5	27.1	14	0.0	0.0
8	31.6	29.5	7	0.0	0.0
9	31.3	29.7	5	0.0	4.0
10	31.3	28.1	10	0.0	6.0
Average	31.4	26.7	15	0.0	2.5

approximate weight (oz.	/sq. yd): 15.4	Standard Deviation: 8.0	Average + 3 SD: 39.0
roduct Configuration: Single Layer Conditioning: Oven at 220°F for ntended End-use (if known & other than drapery): Dra		☐ Multi Layer r minimum 30 minutes pery	☐ 70 ±2°F & 65 ±2%RH for minimum 24 hours
 Where fragmer seconds per sp Where the aver Individual spec Where the spec 	the recorded; however, it is not that sor residues of specimens that or residues of specimens that the sample of 10 specimen for the sample of 10 specimens will be listed as a failure	pecimens, the material shall be re- imens in a sample is greater than if it exceeds mean + 3 SD formance in accordance with eith	ber continue to burn for more than an average of 2
⊠ C	d on the above Results and Ac complies oes Not Comply	ceptance Criteria, the item tested	:
pecified by the standard		tained after testing specimen in ad	ccordance with the procedures and equipment
Berta Stiver			
uthorized Signature			Date Order Completed: 04/22/2024

553 76th Street, Byron Center, MI 49315

P: 616-559-6123 E: testlab@applied-lab.com

Page 1 of 1